

ADDENDUM NO. 1

**Dead Run Force Main Rehabilitation
CONTRACT NO. CN14402004
PROJECT NO. WW-000007-007**

This addendum consists of one (1) page. This addendum is supplementary to the contract documents for the **Dead Run Force Main Rehabilitation** project located on Churchill Road between Dead Run Drive and Fleetwood Road in Fairfax County, Virginia. All revisions, additions or deletions included herein as Addendum No.1 shall become a part of the Contract Documents as if originally called for in the Drawings, Specifications and Form of Bid.

SPECIFICATION SECTION 02530

DELETE: Paragraph 2.1.B.1.a – “HDPE pipe for sewage force main shall be PE 3608 HDPE pipe meeting cell classification 345464 C for black per ASTM D 3350; and shall be listed in the name of the pipe and fitting manufacturer in Plastics Pipe Institute (PPI) with a standard DR-11 class rating.”

ADD: 1. Pipe Material:


- a. HDPE Pipe for sewage force main shall be PE 4710 HDPE pipe meeting cell classification 445574C for black pipe per ASTM D 3350; and shall be listed in the name of the pipe and fitting manufacturer in Plastics Pipe Institute (PPI) with a standard DR-11 Class rating in Iron Pipe Size (IPS).

END OF ADDENDUM NO. 1

Bidders are required to acknowledge receipt of all addenda on Page B-2 of the Form of Bid, Section B. Failure to indicate receipt of any addenda may be cause for rejection of Bid.

COUNTY OF FAIRFAX, VIRGINIA

By:



Brad Melton, Director, Utilities Design & Construction Division
Department of Public Works and Environmental Services