

3 WALLS to be MASONARY

The other (4th) to be STEEL FRAMED with SHEET METAL SIDES slotted to allow FILTER FRAMES removal for Recovering or Renewal with Burlap.

BURLAP SCREENS to be fastened to Filter Frames with Hooks or Pins similar to curtain stretcher.

WATER SPRAY to act as primary paint Coagulator.

— FILTER TOWER for TAG SHOP PAINT ROOM —

DEPARTMENT OF CORRECTIONS		
— ENGINEERING DIVISION —		
APPROVED.	DATE. 23 FEB 1950.	DRAWN. [illegible]