REVISIONS
2 4/6/40
REVISED PLAN AS PER CORRECTED PRINT RECEIVED TODAY
1 3/20/40

PRES. RESET PRESSES

PROP LEG FORM

PROP SLEEVE FORM

PROPOSED UNITS (FOOT POWER)

IRONING BOARDS

PROP SHIRT UNIT

TABLE

TOILETS

PRES. RESET 120" 4 ROLL F.W.IR O.M. FROM D.C.J.

PRESENT 100" 3 ROLL F.W.IR.

PRESENT 120" 6 ROLL F.W.IR.

PROP ZARMOS (FOOT POWER)

PROP 44"x90" TUMBLER ULTRA-SPEED

PRESENT TUMBLERS

40"x90" O.M.

40"x64"

42"x96"

42"x64"

SOAP TANK F.IR.

PRESENT WASHERS

PROP 42"x84" D.C. CHAMPION

PRESENT EXTRACTORS 30" 26"

CONTAINER

RESET JIB CRANE

30" HOTRUX PROP.

48" HOTRUX PRES. RESET

WATER TANK TO BE REMOVED (BY OTHERS)

CONTROL PANEL BOARD

SUGGESTED DOOR

NEW BUILDING
(DESIGNED BY OTHERS)

IN

OUT

TOILET

SOILED RAG STORAGE

ALL CLEAN LINEN STORAGE

SINK

TOILET

TOILET

TUBS (BY OTHERS)

PROP. 20 2-COMP AIRWAY DRYERS

RR FROM D.C.J. 40" O.M.

P.R. FROM P.L. 48" RUMATIC

P.R. FROM D.C.J. 42"x72" O.M.

36"x54" O.M.

P.R. FROM B.OF E. 36"x54" O.M.

36"x54" O.M.

P.R. FROM P.L. 36"x54" O.M.

KEY

O.M. = OTHERMAKE
P.R. = PRESENT RESET
P.L. = PRESENT LAUNDRY
D.C.J. = D.OF C. JAIL
B.OF E. = BUREAU OF ENGRAVING

NOTE!
MINIMUM CEILING HEIGHT DESIRED UNDER BEAMS FT. INCHES

OPENINGS THRU WHICH MACHINES ARE TO BE TAKEN MUST BE AT LEAST 7'-0" WIDE BY 8'-0" HIGH

FLOOR UNDER SUPPORTS OF MACHINES SHOULD BE LEVEL

HIGH PRESSURE STEAM FOR MACHINERY DESIRED AT [illegible] UNLESS OTHERWISE NOTED

COMPRESSED AIR FOR [illegible] AT 70#

LAUNDRY PLAN

FOR THE

DISTRICT REFORMATORY

LORTON VA.

THE AMERICAN LAUNDRY MACHINERY CO.
40 East 34th St. New York City

CONST.	SCALE	SALESMEN	DRAWN BY	CHECKED	DATE	SUPV.
	1/4"=1'-0"	L.C. KUAUS				
		SERVICE ENG. S.M. ROSENFIELD	G.J.JR	Lau	3/20/40	

DATE APPROVED

JOB No. 7138-A 2