EXISTING NORTH WALL

SKEB 36 END BOX

3 EXTRACTORS

5 PIECES OF FVK 366 VERTICAL BUSWAYS EACH 10'-0" LONG = 50'-0"

WASHER NO. 1

WASHER NO. 2

WASHER NO. 3

24" X 24" EDGEWISE ELBOW EIE 366

WASHER NO. 4

EXISTING EAST WALL

SOAP MIXING TUBS

TUB NO. 2

TUB NO. 1

WASHER NO. 7

SKEB 36 END BOX

2 - 10'-0" PIECES OF FVK 366 VERTICAL BUSWAYS = 20'-0"

TUMBLER NO. 1

SHAKER TABLE

FORMULAE ROOM

WASHER NO. 6

3 - 10'-0" PIECES OF FVK 366 VERTICAL BUSWAYS = 30'-0"

WASHER NO. 5

MANGLE

MANGLE

MANGLE

LAUNDRY FED THIS END OF MACHINE

MANGLE

SKEB 36 END BOX

49" X 24" EDGEWISE TEE

8 - 10'-0" PIECES OF FVK 366 VERTICAL BUSWAYS = 80'-0"

TUMBLER NO. 2

10'-6"

CABLE TAP BOX SKCB 36

TUMBLER NO. 4

1 - 3'-0" PC. OF FVK 366-3 VERTICAL BUSWAY

TUMBLER NO. 3

CABLE TAP BOX SKCB 36

2 ONLY NO. 72326 - 3POLE - 3FUSE - 600 AMPERE SWITCHES

18'-7½"

9'-10⅜"

4'-6" X 4'-6" X 6'-6" EXISTING MANHOLE

DUCT THAT IS UNDER DRIVEWAY TO HAVE AN ADDITIONAL 6" CONCRETE SLAB OVER THEM DIRECTLY UNDER BRICK PAVING.

71'-5"

6 - 5" DIA. CONDUITS TO RISE 12" ABOVE FLOOR BACK OF NEW PANEL, EACH TO TERMINATE IN INSULATED BUSHINGS.

2 - 5⅜" x 5⅜" SQ. - 4 WAY DUCTS - EACH DUCT TO HAVE 4 BORES EACH 3½" x 3½" SQUARE

4'-6" X 6'-6" X 6'-6" DEEP MANHOLE

2 EXISTING MANHOLES AT TRANSFORMER VAULT

43'-5½"

REMOVE EXISTING RADIATOR TO NEW LOCATION SHOWN

4'-0" WIDE X 6'-0" HIGH PANEL SET 12" ABOVE FLOOR

NEW LOCATION OF RADIATOR AFTER REMOVAL FROM ITS PRESENT LOCATION

EXISTING PANEL

3'-0"

8'-0"

5'-6"