

Faulty Fire Protection Equipment Report

This report should be utilized to notify the Fire Prevention Division when a fire protection system has activated resulting in a nuisance alarm from any cause or a system has activated properly or failed to activate on any fire event.

FAX THIS REPORT TO THE FIRE PROTECTION SYSTEMS BRANCH AT:

Fairfax County 703-246-9173
City of Fairfax 703-385-9265

Alexandria City 703-838-3880
Prince William Co. 703-792-6492

Arlington County 703-228-4655
Loudoun County 703-737-8595

Unit: _____ Shift: _____ Unit OIC: _____ Jurisdiction: _____

Incident Number: _____ Date: _____ Dispatch Time: _____ Fire Station: _____

Incident Address: _____ Area/Room/Floor: _____

Occupancy Name: _____ Occupancy Type: _____

On-Site Contact: _____ Telephone Number: _____

Property Management: _____ Telephone Number: _____

REASON FOR RESPONSE: (Check the most applicable reason and/or explain in the "Actions Taken & Remarks" section)

Fire Nuisance Alarm - Cause *Unknown* Nuisance Alarm - Cause Known Accidental Alarm - Multiple

CAUSE OF EQUIPMENT OR SYSTEM ACTIVATION: Human Action or Error Unknown

Smoke Detector Duct Detector Heat Detector Manual Pull Station Flow Switch

Sprinkler Head(s) Broken Pipe(s) Dry System Trip Hood System Trip Other Device

Location of Device(s) Causing Alarm: _____

SYSTEM TYPE: Fire Alarm Wet Sprinkler Dry Sprinkler Fire Pump Standpipe

Dwelling Unit Smoke Alarm(s) Wet/Dry Chemical Alternative Extinguishing Agent* FDC

STATUS: Reset/Restored In Alarm Trouble/Supervisory Out-of-Service Unknown

Did Faulty Equipment Initiate the Alarm? Yes No Fire Marshal Notified: _____

ACTIONS TAKEN & REMARKS: Was the Building Owner Notified of Actions Taken? Yes No

*Notify Hazardous Materials Services for all Halon, FE-13, FM-200, Intergen, CO₂, & foam system discharges