SWIMMING POOL INSPECTION REPORT CONTINUATION FORM

FAIRFAX COUNTY HEALTH DEPARTMENT
DIVISION OF ENVIRONMENTAL HEALTH
10777 MAIN STREET, SUITE 102
FAIRFAX, VA 22030

TELEPHONE (703) 246-8417
FAX (703) 278-8157
TDD (703) 591-6435

ESTABLISHMENT NAME: PROVIDENCE CENTER

MO	DAY	YR
02	11	09

ADDRESS: 7525 MARC DRIVE; FALLS CHURCH

VIOLATION DESCRIPTIONS/CORRECTIONS

NEW AQUASTAR ANTIENTRAPMENT COVERS INSTALLED ON MAIN DRAINS OF POOL. SAME ANTIENTRAPMENT GRATES ON UPPER & LOWER SPAS AS AT 12/1/08 INSP. CONFIRMED WITH NV POOLS WHICH SCOPED & DYED ALL SPA SUCTION OUTLETS THAT EACH SPA PUMP IS SERVED BY DUAL SUCTION OUTLETS (DOCUMENTATION IN FILE).

FACILITY IS CURRENTLY IN COMPLIANCE WITH THE VIRGINIA GRAYME BAKER POOL & SPA SAFETY ACT.

RECEIVED BY: [signature] NAME

INSPECTED BY: [signature] ENVIRONMENTAL HEALTH SPECIALIST

Rev. 4/05