



County of Fairfax, Virginia

ADDENDUM

DATE: May 28, 2020

ADDENDUM NO. 3

TO: ALL PROSPECTIVE OFFERORS

REFERENCE: RFP 2000003120

TITLE: Sewer Rehabilitation

DUE DATE/TIME: June 5, 2020 @ 10:00 a.m.

The referenced Request for Proposal is amended as follows:

1. The following are corrections being made to Attachment C:
 - a. **Change** the Unit for Item 1 from "LS" to "EA".
 - b. **Delete** the word "per tap" and **replace** with "per joint" in the description of Items 39 through 40.
2. Refer to Attachment 1 in this document for responses to questions received.

All other terms and conditions remain the same.

Nicole Cifci, CPPB, VCA
Contract Specialist II

THIS ADDENDUM IS ACKNOWLEDGED AND IS CONSIDERED A PART OF THE SUBJECT REQUEST FOR PROPOSAL:

Name of Firm

(Signature)

(Date)

A SIGNED COPY OF THIS ADDENDUM MUST BE RETURNED PRIOR TO DUE DATE/TIME OR MUST ACCOMPANY PROPOSAL BY WAY OF UPLOAD TO FAIRFAX COUNTY'S PROCUREMENT PORTAL AT [HTTPS://FAIRFAXCOUNTY.BONFIREHUB.COM](https://fairfaxcounty.bonfirehub.com).

NOTE: SIGNATURE ON THIS ADDENDUM DOES NOT SUBSTITUTE FOR YOUR SIGNATURE ON THE ORIGINAL RFP DOCUMENT. THE ORIGINAL PROPOSAL DOCUMENT MUST BE SIGNED.

Department of Procurement and Material Management
12000 Government Center Parkway, Suite 427
Fairfax, VA 22035
Website: www.fairfaxcounty.gov/procurement
Phone: 703-324-3206, **TTY:** 711, **Fax:** 703-324-3228

ATTACHMENT 1

- Q1. As this is a Unit Price RFP with indefinite quantities and Task Order Driven, and the bidder does not know the ultimate quantity or value of work, can a line item be included on the Cost Proposal for the Contract Bonds for this project? That way, all Bond Costs are recovered, where if spread throughout the bid items, there is a possibility the Bond Costs may not be fully be captured if work is not done or quantities achieved for certain bid items of work.
- A1. The County does not want a separate cost for bonds, all costs should be incorporated into the individual line items on the pricing schedule.**
- Q2. The Bid Form description for Bid Items 39 through 45 reads ...up to ____ gallons per tap. The Bid Unit Price UOM reads per each and Sec 1025 Para 2.15B Measurement for Payment reads per each joint. Please clarify the description in the bid form that it should read per each joint and not per each tap?
- A2. The description for items 39-45 should read “per joint” not “per tap.” Please reference Item 1b above.**
- Q3. The Bid Form Bid Item 1, UOM reads Lump Sum with quantity of 1 for Emergent and Large Planned Work. Per Sec 1025 Para 2.1B, the Payment will be for Each Occurrence when special and or emergent work is required. The Cost Proposal for Bid Item 1 UOM should be for each, correct?
- A3. The UOM for Item 1 should be for each occurrence or “EA”. Please reference Item 1a above.**
- Q4. Are Bid Items 34-36 trenchless “no-dig” repairs or external “open cut” repairs? It is not clear in the Specs for Measurement and Payment 1025 2.11 to 2.13 and Sec 2954 if they are. Please clarify as all other items in the Cost Proposal Category are trenchless methods.
- A4. Items 34-36 are to be completed using trenchless methods, no excavation.**
- Q5. Per Section 2953 Para. 3.1.D6 the liner is radially expanded by mechanical means...until the liner contacts the inside wall of the existing pipe. How is it confirmed / guaranteed that that the liner makes and maintains contact with the inside wall of the existing pipe after mechanically expanded?
- A5. Verification of contact with the wall should be in accordance with the manufacturer’s recommendations and instructions.**
- Q6. Why is Steam Cured CIPP not allowed for this project? The process is an acceptable means and methods for curing CIPP Liners all over the world, is less disruptive for customers due to decreased liner processing time with shorter outage times, and provides the same finished product as Hot Water Heat Curing, meeting the contract physical properties of the liners.
- A6. Owner preference.**
- Q7. Per Section 2959 Para 2.1.E requires the volume of mixed grout pumped be measured and recorded for each grouted joint/connection. Does this measurement and recordation need to be performed electronically?
- A7. It is a VDOT requirement for thickness to be a minimum of 1.5 inches. For additional information contact VDOT at <http://www.virginiadot.org>.**