



## SWIMMING POOLS and SPAS Electrical Inspection Report and Certification

THE FOLLOWING IS A GUIDELINE TO THE ANNUAL POOL/SPA INSPECTION REPORT. PLEASE NOTE THAT THIS IS ONLY A GUIDELINE AND ANY VIOLATIONS OF THE APPLICABLE SECTIONS OF THE NATIONAL ELECTRICAL CODE AND THEIR CORRECTIONS ARE THE SOLE RESPONSIBILITY OF THE CERTIFYING PARTY.

**Permit No.**

--	--	--	--	--

The following items are found to be in compliance with the <b>NATIONAL ELECTRICAL CODE</b>	Complies with Code
<b>LUMINAIRES (Light Fixtures) in the POOL/SPA</b>	
GFCI protection for luminaires underwater  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
If underwater luminaires are not GFCI protected, was the pool/spa filled with water prior to inspection?  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
Underwater luminaires checked for leakage from damaged or broken lens and/or gaskets  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
Non-functioning pool/spa underwater luminaires replaced/repaired  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
<b>EQUIPOTENTIAL BONDING</b>	
A minimum of a #8 solid copper conductor was used to bond pool/spa and associated equipment  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
Bonding of Deck Boxes  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A

The following items are found to be in compliance with the <b>NATIONAL ELECTRICAL CODE</b>	Complies with Code
<b>EQUIPOTENTIAL BONDING (CONT.)</b>	
Bonding of all metal housings for motors, pumps, heaters, chlorinators, etc  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
Metal Valves on PVC pipe are bonded  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
Bonding of all metal components that are located within 1.5m (5ft) horizontally of the inside wall of the pool/spa and within 3.7m (12ft) measured vertically above the maximum water level of the pool, or any observation stands, towers, platforms, or any diving structures  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
<b>ELECTRICAL EQUIPMENT</b>	
GFCI devices and over-current devices are verified to be in good working condition  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
Connection in deck boxes are tight and secure  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
Outlets, devices, junction boxes, deck boxes, conduit body fittings and motor terminal housings are properly covered  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
All feeders, branch circuits, and electrical equipment have properly-sized over-current protection  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A
Equipment grounding conductor is connected to all receptacles, devices, luminaires, motors, pumps, and electrical equipment  Deficiencies Noted: Deficiencies Corrected:	<input type="checkbox"/> YES <input type="checkbox"/> NO <input type="checkbox"/> N/A

The deficiencies found and corrected that were not within the preceding guidelines are as follows: